

WASTEWATER TREATMENT SYSTEMS

A Leader In Wastewater Jechnology Since 1965.

100 Patent No. 5,268,094

Cromaglass Wastewater Treatment Systems

DESIGNED as a continuously fed activated sludge process with clarifiers that are operated on a batch basis.

All **Cromaglass** treatment systems operate on identical principles: Turbulent aeration of incoming wastes and batch treatment of bio-mass in separate aeration and quiescent settling chamber.

DISCHARGED effluent is an odorless liquid, almost clear in color, with a reduction in BOD and Suspended Solids over 90%. Even higher efficiencies can be achieved if required.

DENITRIFICATION is now mandated in many areas and *Cromaglass Systems* are capable of Denitrification with the addition of an anoxic cycle.

Per-batch cycling is 120-240 minutes. Optimum quality standards are maintained even at peak intake levels because of batch-transfer and batchreserve functions.

Proven effluent quality is attested to by independent laboratory research and testing. National standards such as established by the National Sanitation Foundation and Federal EPA have been surpassed. Effluent quality is accepted for RECYCLE use with irrigation and toilet flushing.

TYPICAL CYCLE

FILL: AERATION

Flow enters the Solids Retention Section (A) which is separated by noncorrosive screen. Inorganic solids are retained behind the screen. Organic solids are broken by turbulence created with mixed liquor being forced through screen by submersible aeration pumps. This eliminates the need for mechanical comminution.

AERATION

Liquid and small organic solids pass through the screen into the continuing Aeration Section (B). Air and mixing are provided by submersible pumps with venturi aspirators that receive air through pipe intake from the atmosphere.

DENITRIFICATION (OPTIONAL)

Provided by an anoxic period during the regular treatment cycle. *Cromaglass* units create anoxic conditions by closing the air intakes of the aeration pumps with electric valves. This stops aeration, but the system continue mixing.

TRANSFER/SETTLE

Treated mixed liquor is transferred by pumping to the Clarification Section (C). The transfer period overfills the Clarifier with the excess spilling through overflow weirs back into the main Aeration Section. Transfer ceases and Clarifier (C) is isolated – solids separation occurs under quiescent conditions.

DISCHARGE

After settling, effluent is pumped out of the Clarifier (C) for discharge. Return sludge is from the bottom of the Clarifier (C) back into the main Aeration Section (B) using a submersible pump, or sludge can be wasted to a Sludge Processing Tank.









Thoroughly Tested

- Modular Construction
- Easily Expanded
- Lightweight

CROMAGLASS® BENEFITS

- No Offensive Noise or Odors
- · Easily Installed
- Positive Discharge
- "Flow Thru" Eliminated

- Accepts Overload
- Automatic Controls
- Monitoring 24 Hours
- Noncorrosive



Cromaglass Wastewater Treatment Systems are essentially Sequencing Batch Reactors (SBR) as opposed to conventional continuous flow activated sludge systems. Treatment is by timed sequences within a single vessel. Continuous flow systems require several vessels, using a larger land area and higher installation costs.

Because time functions can easily be changed, an SBR provides custom treatment dependent on varying hydraulic and biological loading up to the designed capacity of the system.

Cromaglass Systems can be installed in modules, meaning a lower initial investment. The system can start with one independent module designed to treat the initial loading.

As development grows, additional modules can be added as needed.

Modules can be added at the initial site, or if more economical, a new treatment site can be used.

Because a batch system requires less land area, it can be placed in multiple locations – saving additional piping/pumping cost.



CROMAWATCH I/P

Cromaglass Corporation has introduced one of the industry's first remote monitoring of wastewater treatment systems.



With the use of a unique combination of controls, computers and internet connection, the plant operator and *Cromaglass* technician can remotely monitor and modify *Cromaglass* systems anywhere in the world.

Cromaglass Site – the controls for this System can be accessed anywhere in the world vla the Internet.



NOISE AND ODORS CONTROLLED

Attractive tank modules with lockable maintenance hatchways enable *Cromaglass Systems* to be installed without odors or noise associated with other types of open sewage treatment plants, when operated properly. Tanks can be installed below ground close to buildings being served – saving unneeded pipe and/or pump expense.

BY-PASS NOT POSSIBLE

Cromaglass Systems are designed to make bypass and intertank contamination impossible. When operated properly, no bio-mass can transfer from one section to another except through the programmed pumping system. All sludge collected in the settling chamber is automatically returned to the aeration section for further aeration and breakdown. This results in low sludge accumulation. Most residual sludge that collects is made up of biological ash and insoluble particles. Sludge can also be wasted to a Sludge Processing Tank.



MAXIMUM OPERATIONAL FLEXIBILITY PROVIDED BY PLC CONTROLS

State-of-the-Art PLC controls will respond to the inputs from level sensors. The PLC automatically adjusts treatment parameters in response to changes detected in the influent flow. It can store a permanent record of all operational functions, which provides information on each function of each cycle for whatever time reference desired. Such information can indicate if service or maintenance is needed, and the operator can then schedule it before a failure occurs.

STRONG, LIGHTWEIGHT, and REUSABLE

Corrosion-proof vessel construction of strong, lightweight fiberglass. Covers and locking hatches are also of fiberglass. Tanks are constructed to withstand pressure involved when installed at acceptable depths below ground. Being light in weight means expensive cranes are not required, saving installation costs. Because *Cromaglass Systems* are completely integrated, compact and transportable, they can be reused, relocated and/or resold when changing circumstances warrant.



Lightweight fiberglass modules being off loaded and set in place in the excavation/concrete pad. This is typically done by backhoe used to excavate the site.

PROVEN QUALITY

Assurance of treatment quality has been accomplished through independent laboratory research and testing supported by sampling from installed systems (results available upon request). National Standards as established by Federal EPA and the National Sanitation Foundation have been surpassed. Effluent quality with over 90-95% reduction of BOD and Suspended Solids enables *Cromaglass* to be used where other methods are not acceptable. Recycled effluent is currently being used for landscape irrigation and as a toilet flushing medium.



Effluent Sample from Model CA-120 Showing Surface Discharge by Irrigation System.

COST-EFFECTIVE SMALL COMMUNITY SYSTEMS

Treatment of wastewater in small communities and schools located beyond a municipal system presents a challenge to consulting engineers. *Cromaglass Systems* offer a cost-effective alternative solution. Many of these professionals have turned to the *Cromaglass Batch Treat Process*, an alternative and innovative technology assessed favorably by Federal EPA to be used where conventional sewerage systems are unavailable or not cost effective. This modular concept design has proven less costly and more environmentally sound than other sewerage installations. Several schools as well as small community projects have specified *Cromaglass*.

REDUCED DRAIN FIELD SIZE AND SURFACE DISCHARGE CAPABILITIES

Because of the clear, odorless quality and high treatment standards of *Cromaglass Systems*, drain field size can be reduced substantially from that required for conventional systems. With optional disinfection added, these systems are permitted for surface discharge under conditions normally unsuitable for sub-surface disposal.



All tanks in place ready for backfill. Note concrete pads and stainless steel tie-down rods.

ADEQUATE OVERLOAD RESERVE

Batch Processing is capable of high treatment even under a wide range of flows as found in growing communities. Also with varying organic loadings of commercial, school and institutional use, excellent effluent standards are maintained. This feature is an integral part of the system to cover temporary emergencies or upsets.



Tomaglass BATCH TREATMENT PROCESS Residential · Commercial · Industrial

9186 (34.8)

9186 (34.8)

9186 (34.8)

100a - 230v

100a - 230v

100a - 230v

60/78

60/78*

82/100*

SPECIFICATIONS

POWER	7:													
115v/230v - Single Phase						PUMPS	TC	TOTAL HEAD - FEET (METERS		RS)	S) AMPERAGE			
230	v/460v – 3 ł Ja/60 Ma	Phase avai	lable					5 (1.52)	5 (1.52) 10 (3.05) 15 (4.57)		20 (6.10)	(6.10) 25 (7.62)		LOCKED
SU HIZ/OU HIZ						MODEL	- Clines	CADACITY - C Dia (LONA) and (LONA)				RUN	ROTOR	
Non	on 1 ancion	• iro etandai	rel.						CAPAC	T - QLP-A	no (comment)		pint s	
Nen	na 3R 4 7	and 12 ava	allahle			0	1/3 H.P.	52 (114)	42 (98)	29 (76)	16 (45)		12	15.6
ALARN	1. on, 9, 7.	and te ave	anabie			-	DISCHARGE				-			
Red	Light mount	led on nan	el with onti	onal audibl	e alarm		1/3 H.P.	85 (322)	70 (265)	52 (197)	35 (192)	14 (53)	10.7	32.2
Cro	maWatch I/	p	er man ope		o chann	1	WE0311M 1/2 H.P. WS0511B	150 (567) 1	10 (200) 1 05 1	OC LIDIT	0) 52 (196) 8	14 (00)	(30) 14.5	
CONST	BUCTION I	MATERIAL	S:							120 (454) 90 (340)				34.9
Tan	k – Fiberala	ŝŝ				1			120 (454			8 (30)		
Comminution Chamber - Fiberolass and stainless steel screen					een -	-	-	-	-	-				
Pipi	ng and Fittir	ngs - Sche	dule 40 an	d Schedule	80 PVC		1 H.P.		180 (681	157 (595)	127 (481)	95 (360)	12.3	1
Met	al Fittings -	Stainless	steel				and to the o							
	10			1	DITIONA	L SYSTE	M SPECI	FICATIO	NS	24	97	i hat to		
				SHIPPING	24 HR. MAX.	STNDRD	STNDRD	DENITE		DENITE	ELECTRIC	AL TA	NK	TOTAL AMPS
MODEL	LENGTH	WIDTH	HEIGHT	WEIGHT LBS. (KG.)	CAPACITY GALS. (MP)	DISCHG. VOL GALS. (MP)	DISCHG. PER DAY	DISCHAR VOL GALS	IGE DI	SCHARGE PER DAY	CONSUMPT KWH/24 HF	ION VOL	.UME S. (M ³⁹)	REQUIRED 120v/230v
CA-5	7'11" (2.4m)	57" (1.7m)	5'7' (1.7m)	652 (296)	500 (1.9)	65 (.32)	6	ri/a		n/a	8.0	92	3 (3.5)	15a - 120v
CA-12	11'3° (3.4m)	57" (1.7m)	57" (1.7m)	967 (439)	1200 (4,5)	200 (.76)	б	800 (3.	0)	4	8.0	135	8 (5.1)	15a - 120v
CA-15	11'3" (3.4m)	57º (1.7m)	57º (1.7m)	967 (439)	1500 (5.7)	250 (.95)	6	1000 (3.	8)	4	10.0	135	8 (5.1)	20a - 120v
CA-25	14'10" (4.5m)	6'10" (2.1m)	6'10" (2.1m)	1720 (780)	2500 (9.5)	420 (1.6)	6	n/a		n/a.	21.0	2910	(11.0)	40a - 120v
CA-30	14'10" (4.5m)	6'10" (2.1m)	6'10" (2.1m)	2070 (939)	3000 (11.4)	375 (1.42)	â	2250 (8.	5)	6	55/66*	2910	(11.0)	60a - 230v
CA-50	19'5" (5.9m)	7'4" (2.2m)	8'3" (2.5m)	2684 (1217)	5000 (18.9)	625 (2.37)	8	3750 (1/	1.2)	6	55/65*	4590	(17.4)	60a - 230v
PA	ADDED OF DUS	man in the case	statement and reasons	anal least	and the second second	20010 000	1.45	20000 147	1.00		and other and	1000	14- 44	man manager

* Dependent on biological and hydraulic loading, electrical consumption may vary.

4885 (2216) 10,000 (37.9)

4885 (2216) 12,000 (45.4)

15.000 (56.8)

' System Specifications are subject to change without notice.

42'10" (13.1m) 7'4" (2.2m) 8'3" (2.5m) 4950 (2245)

42'10' (13.1m) 7'4" (2.2m) 8'3" (2.5m)

CA-120 42'10" (13.1m) 7'4" (2.2m) 8'3" (2.5m)

+ Larger sizes now available

CA-100

CA-150

1

9

6



10

12

12

6000 (22.7)

6000 (22.7)

7500 (28.4)

6

6

1000 (3.79)

1000 (3.79)

1250 (4.73)

CROMAGLASS Corporation

P.O. Box 3215, 2902 North Reach Road Williamsport, PA 17701 Phone: (570) 326-3396 · Fax: (570) 326-6426 Email: mailinfo@cromaglass.com · www.cromaglass.com Represented by:





WASTEWATER TREATMENT SYSTEMS

OPERATIONS & MAINTENANCE MANUAL

CROMAGLASS CORPORATION Williamsport, Pennsylvania

Note from Water Authority-Cayman:

The following information is for quick reference. It consists of excerpted pages from a multi-section Cromaglass manual for models CA 50& CA60. A complete manual shall be provided for each system sold.

SECTION I

INTRODUCTION

A. Operations Manual User Guide

- 1. This manual was written to provide technical guidance for the owners/operators of the Cromaglass Sequencing Batch Reactor (SBR) models CA-50/60.
- 2. Information presented is necessary to operate and maintain the Cromaglass SBR system.

B. Operator Responsibility

- 1. The Operations & Maintenance Manual can be used either as a guide for an individual familiar with operations of a sewage treatment facility, or as a valuable tool to supplement the training of an inexperienced person. The material contained in this manual is presented to promote normal operating conditions. In the course of time, operating personnel will be called upon to exercise their skill and judgment when unusual operating conditions are encountered. Experienced and inexperienced persons can take advantage of the information offered concerning sewage treatment plant operations.
- 2. The operator should maintain accurate and legible operational maintenance records.
 - a. An operator logbook is essential to good record keeping. This enables the operator to track process control strategies. The type of information recommended should include but not be limited to:
 - (1) Date, weather
 - (2) Operator on staff and signature
 - (3) Current average daily flow
 - (4) Current number of cycles per day
 - (5) Dissolved oxygen content
 - (6) Microscopic examination
 - (7) Equipment breakdown, report on repair status
 - (8) Current phase times for aeration, anoxic, settle, discharge
 - (9) Any and all changes to time clocks
 - (10) Volume of sludge wasted in gallons per day.
 - b. The information should be entered daily, as necessary, into the logbook. This should be standard operating procedure for all personnel.

C. Purpose of Operations & Maintenance Manual

- 1. The purpose of this manual is to act as a training tool for new operators and a guide for experienced operators.
- 2. The format of this manual is to provide the operator with detailed instructions on the operation of each piece of equipment.

D. General Type of Treatment and Treatment Requirements/ Effluent Limitations

Influent

5,000 gpd (CA-50) w/ Denitrification 3,750 gpd
6,000 gpd (CA-60) w/ Denitrification 3,750 gpd
300 mg/l (CA-50) 227 w/Denitrification
250 mg/l (CA-60) 227 w/Denitrification
SS) 270 mg/l/227mg/l w/Denitrification
35 mg/l
55 mg/l

<u>Effluent</u>

BOD-C (Carbonaceous)	≤ 25 mg/l
Total Suspended Solids	≤ 30 mg/l
Total Nitrogen	\leq 10 mg/l (with denitrification capability)
TKN	\leq 20 mg/l (with nitrification)

E. Description Of System Components

- 1. The Cromaglass CA-50/60 consists of the following components:
 - a. Tank 1 of 1:
 - Solids Retention Section

 (1) High Water Alarm
 - Aeration Section
 - (1) Aeration Pumps P1 & P2
 - (2) Aeration/Transfer Pump P3
 - (3) Dual Aeration Float (C)
 - (4) Low Water Discharge Float (LWDF)
 - Contact Clarifier
 - (1) Sludge Return Pump P4
 - (2) Sludge Return Shutoff Float (F4)
 - (3) Redundant Discharge Pumps P5 & P6
 - (4) Discharge Pump Failure Alarm Float (H)
 - (5) Discharge Pump Shutoff Float (DF)
- 3. Section view diagrams of these components are located in this manual Section II.



Page 2-2

SECTION III

PROCESS SUMMARY

Effective reduction of organic material entering the Cromaglass Sequencing Batch Reactor (SBR) is accomplished biologically through millions of microorganisms (bacteria). These bacteria degrade wastewater through the addition of atmospheric oxygen and biochemical reactions. Through the operation of automatic time clocks, the Cromaglass SBR maintains a controlled environment. This enables various process control strategies to be achieved.

The Cromaglass SBR process descriptions are as follows:

- A. <u>Screening/Pre-Aeration</u> Raw wastewater enters the solids retention section for a separation process of organic biochemical oxygen demand (BOD)/ inorganic materials (e.g., toilet paper, feminine hygiene products, etc.). This reduces the potential for any of the above to become lodged in any of the pumps and prevent normal operations.
- B. <u>Aeration</u> This is the phase for biological degradation of organic material thereby reducing pollutants. At pre-programmed times, submersible pumps are activated to provide adequate mixing to allow BOD and bacteria (workers) to come in contact with one another. The dissolved oxygen is supplied via pumps when the wastewater is directed through a unique air induction device. As wastewater is being pumped, atmospheric oxygen is drawn into the intakes provided. This supplies the aerobic bacteria with an energy source for growth and reproduction. As the microorganisms consume the organic waste, additional waste is created.

This is the whole basis of the activated sludge process: organic material as the food source placed into an aerobic environment with microorganisms serving as the workers in the absence of other extraneous conditions (e.g., pH, toxicity, low levels of alkalinity, low dissolved oxygen). All of this working together with adequate retention time for the biological/chemical reactions occurring should produce a quality effluent (treated sewage).

- C. Anoxic/Denitrification This phase refers to the degradation of inorganic byproducts of Ammonia Nitrogen (NH₃-N) to gaseous nitrogen and CO₂ in the absence of dissolved oxygen. This process becomes important in selected geographical areas due to high concentrations of nitrates found in drinking water. High levels of nitrates sometimes found in soils have been linked to a disease known as methomoglobinimia or BLUE BABY SYNDROME. The Cromaglass SBR has the capability to create an environment, which can ultimately reduce these concentrations to a safe level for human consumption. This is accomplished via control valve placed in line with an existing air pipe. Following the aeration cycle, most of the Ammonia Nitrogen levels have been reduced to nitrates (NO₃). Automatically controlled air valves close, thus creating an environment with little or no free oxygen present. Specific bacteria already contained in the system begin to utilize available NO₃ as an oxygen source for energy. Through careful monitoring, these NO₃ levels are eliminated or reduced to levels that pose no threat to human consumption.
- **D.** <u>Settling</u>- The specific intent for this phase is to provide a quiescent environment (i.e., in the absence of air and mixing) such that solid/liquid separation occurs. The aerobic bacteria, through the introduction of oxygen, mixing, and food, begin to secrete mucoproteins and polysaccharides that provide a sticky surface for sludge particles to adhere to. As a result, the sludge particles coagulate to form a mass (floc) which has a high specific gravity. The dense floc is now permitted to settle to the bottom of the clarifier and the clear effluent (supernate) remains above. This effluent is high quality; virtually free from BOD and total suspended solids.
- E. <u>Decant</u> All processes thus far have been biological in nature. The microorganisms have provided the tools necessary to degrade the waste to an environmentally safe product. Submersible decant pumps, located in the clarifier compartment, are activated automatically through the remote control panel. Once running, a floatable discharge suction line begins to remove the supernatant and dispose to the predesignated source (e.g., sub-surface drain field, surface water supply, etc.).

SECTION IV

CROMAGLASS TREATMENT PROCESS DESCRIPTION

The Cromaglass Sequencing Batch Reactor stabilizes wastewater and reduces organics through aerobic treatment. Utilizing the stages previously listed, the environment is manipulated in order to allow the enzyme systems for selected bacteria to operate more efficiently. By understanding these enzyme mechanisms, we can utilize the batch mode of treatment to achieve very specific goals (i.e., final effluent treatment objectives).

The Cromaglass SBR uses this biological tool to achieve the following results:

- Reduction of Carbonaceous BOD (i.e., particulate and soluble BOD).
- Reduction of Nitrogenous BOD (i.e., ammonia, proteins, etc.).

BOD removal involves the addition of oxygen to create an environment, which allows these bacteria to perform their duties. Once a specific concentration of oxygen becomes dissolved in the wastewater, organic pollutants are broken down into simpler components for bacterial assimilation. This represents <u>Step 1</u> for biological treatment. <u>Step 2</u> involves reduction NBOD. This is the required environment for the heterotrophic bacteria, in the absence of oxygen, to utilize their enzyme systems capable of reducing oxidized nitrogen (i.e., denitrification).

The Cromaglass treatment process involves the following phases:

- <u>Step 1</u>: Aerobic/Aeration
- <u>Step 2</u>: Anoxic/Denitrification
- Step 3: Settling
- Step 4: Discharge

Step 1: Aerobic/Aeration

Addition of air is accomplished via submersible pumps identified as P1, 2, & 3 located in aeration compartment. (Refer to diagrams Section II). As well as supplying oxygen to the system, these pumps also provide adequate mixing to allow the wastewater and bacteria to come in contact. This is of utmost importance to facilitate the waste degradation process. Biological reduction of Ammonia Nitrogen (NH₃-N) proceeds once BOD levels fall below inhibition thresholds - typically 5–80 mg/l low molecular weight soluble BOD. During this process, alkalinity is destroyed via production of nitrous acid. Since nitrifying bacteria utilize bicarbonate alkalinity as a source for structural growth and reproduction, it becomes very important to monitor alkalinity levels within the aeration basin for process control.

It must be noted that pH and alkalinity should not be considered synonymous.

Nitrifying bacteria will be inhibited if sufficient alkalinity is not present, regardless of pH. Approximately 7.14 mg of alkalinity is destroyed to convert 1 mg of Ammonia Nitrogen to nitrite. The second biochemical reaction involves the conversion of nitrite to nitrate also under aerobic conditions. Three pumps are designated to mix/aerate for a pre-programmed time dependent upon treatment objectives.

Step 2: Anoxic/Denitrification

Denitrification is the biological conversion of nitrate-nitrogen to more reduced forms, ultimately di-nitrogen gas. Nitrogen removal occurs when the nitrogen gas is allowed to escape into the atmosphere. Denitrification is brought about by a variety of facultative bacteria that utilize nitrate instead of oxygen for respiration. Alkalinity is produced during this process due to the de-animation of organic compounds. Approximately ½ of the alkalinity destroyed during nitrification is replaced during denitrification resulting in a slight increase in pH. The organic source available and its relative concentration dictate the rate of denitrification. Rates are highest with a readily biodegradable source, such as methanol. Rates also increase with increasing temperature and with decreasing oxygen concentrations.

At pre-programmed times, aeration pumps P1 & 2 along with aeration/transfer pump P3 continue to run without the introduction of air. This can occur via electrically operated solenoid valves which close the air supply to the system. The programmed time is to allow the facultative bacteria to consume all available dissolved oxygen and nitrate. The duration of the cycle is determined via the analysis of the mixed liquor suspended solids filtrate for dissolved NO₃. At completion, the air valve will automatically re-open and the aeration process will resume for another batch.

Step 3: Settling

Following BOD oxidation, nitrogen removal, and subsequent nitrate removal, the Cromaglass SBR process will enter into a quiescent period for solid/liquid separation. This is accomplished by the deactivation of pump P3 via pre-programmed time clock. The unique attribute of a Cromaglass SBR versus a conventional flow through system is found in the clarifier compartment. During settle phase, no additional flow is allowed to enter this compartment, thus minimizing short circuiting or solids washout. This process control allows the bacteria to efficiently utilize the space provided, and polish the effluent.

Following 30 minutes of settling, concentrated sludge is either returned back to the preaeration chamber for additional treatment or wasted to an optional sludge holding tank through the operation of P4. This represents the primary control tool available to the operator for maintaining a specific food to microorganism (F/M) ratio. By controlling the biomass inventory in the treatment process relative to the amount of food contained in wastewater, a healthy population of heterotrophic and autotrophic bacteria can be maintained for treating additional wastewater. This is the primary objective behind activated sludge.

Step 4: Discharge

In order to complete the SBR batch process, a known volume of clear settled supernatant is discharged following an additional settling period of 30 minutes. A 30-minute pump cycle is designated to remove approximately 625 gallons from the clarifier compartment. Pumps P5 & 6 are allocated for this task. The clear supernatant is pumped via floatable suction line and is designed to shut off before entering the settled sludge blanket. The pump shut-off is controlled via float switch (DF) suspended in the clarifier.

An important item to note: In order for a discharge cycle to occur, both the clarifier discharge shut-off float (DF) and the low water discharge float (LWDF) must be activated. Both must be either on their side or inverted. This prevents the pumps from operating out of water, and retains a quantity of activated sludge for treating additional waste. Should the level fail to drop below the H-Float in seven minutes, the discharge pump failure alarm will be activated.

F. IMPORTANT PRECAUTIONS

- 1. Do not allow water softener backwash into the treatment plant. The high concentration of sodium ions will adversely affect the treatment and discharge efficiency
- If restaurant waste is included in the sewage flow, a grease removal unit must be utilized before the sewage enters the plant. This grease removal unit must be properly maintained.
- 3. Laundry waste should not comprise more than 15-20% of the total daily waste flow.
- 4. Do not attach any groundwater, storm water, or condensate drains into the sewage treatment system.
- 5. Non-biodegradable materials (sanitary napkins, applicators, diapers, plastic or rubber goods, cigarettes, hair, etc.) should be placed in the garbage, not introduced into the sewage flow. They can interrupt the treatment process and cause unnecessary service expense.
- 6. Chemicals such as acid, caustic cleaners, gasoline, oil, turpentine, photo developing fluids, etc. should not be introduced into the sewage treatment plant. Disposal of cleaning disinfectants and chlorine bleaches should be kept to normal domestic use. Excessive amounts of these materials can do serious harm to the biological treatment process.
- 7. The use of low-suds, biodegradable detergents are recommended. Excessive use of detergents, or the use of high-suds detergents can cause foaming and odor problems.

SECTION VIII

HOW IT WORKS

A. OPERATING INSTRUCTIONS - PLC CONTROLS Models CA-50/60

Cromaglass Systems are designed to operate most efficiently if installed, operated, and serviced by a contractor experienced in the field of sewage disposal systems. This operational information should enable the operator of the treatment system to understand the batch-treat process and sequence of events that take place.

CONTENTS

The PLC

- 1. Tank Components
- 2. Denite Operation (optional)
- 3. Air Flow
- 4. Powering
- 5. On-Demand Aeration
- 6. Discharge
- 7. Go-Fast Sequence
- 8. Reset Push Button
- 9. High Water Alarm
- 10. Surge Cycle
- 11. Low Aeration Section Alarm
- 12. Low Clarifier Section Alarm

THE PROGRAMMABLE LOGIC CONTROLLER (PLC)

The PLC is the control center for all system operations. With necessary equipment the system operator can fine-tune the operating parameters to optimize the performance of the treatment system dependent on influent characteristics. The standard factory setting of the PLC is for 8 or 10 batch cycles per day for non-denitrification systems. All denite installations are programmed for "6 batch" cycles per day. Operator can adjust these factory settings if necessary.

1. TANK COMPONENTS

Contains the Solids Retention Chamber and the first section of the Aeration Chamber. Pump #1 (P1) and Pump #2 (P2) are the main aeration pumps. They are energized when PLC output relays close (see input/output list). The standard factory setting is to operate P1 and P2 alternately each cycle or both pumps are energized by the "C" float level sensor as the liquid level in the tank increases.

Pumps #3 (P3) aerates and transfers the mixed liquor from the aeration section into the clarifier. P3 is energized by its corresponding PLC relay output during the aeration/transfer

CROMAGLASS Sequencing Batch Reactor Operations & Maintenance Manual CA-50/60

phase. It is de-energized by the PLC after the aeration/transfer preset phase time has elapsed.

Pump #4 (P4) is the sludge return pump located at the bottom of the clarifier. Thirty (30) minutes after transfer into the clarifier stops P4 is energized by the PLC which closes its relay output. P4 then returns sludge that has settled to the bottom of the Clarifier. P4 is wired through the "F4" float level sensor which will stop P4 after a set amount of sludge has been returned to the front of the system, or wasted to a Sludge Processing Tank, as determined by the operator.

Pumps #5 (P5) and #6 (P6) are the discharge pumps. Sixty (60) minutes after transfer stops and the clarifier settles and returns sludge, the PLC energizes either P5 or P6 through relay outputs to discharge 600-625 gallons of treated effluent. P5 and P6 alternate each cycle.

2. DENITE OPERATION (OPTIONAL)

To accomplish denitrification the PLC is programmed to periodically interrupt the aeration cycle by closing the electrically operated air intake valve. The aeration pump(s) continues to circulate the liquid throughout the tanks and with no oxygen available the dissolved oxygen (DO) levels in the mixed liquor drop and denitrifying bacteria then convert nitrate to nitrogen gas and water. All of these functions are controlled by the PLC. A typical treatment sequence is as follows:

1.	Aerate	1.0 hr
2.	Anoxic	1.5 hr
3.	Settle	1.0 hr
4.	Decant	<u>0.5</u> hr
		4.0 hrs

During the Settle and Decant periods the Clarifier is isolated from the other sections and is quiescent while aeration continues in the Aeration and Solids Retention Sections.

3. AIR FLOW

To assure that the electronic valve in the airline is functioning properly it should be checked during the anoxic cycle. During this period no air should enter the system through the air intake pipe. This can be confirmed by placing your hand over the intake opening; no suction force indicates the valve is closed. When the anoxic period ends air should again enter the system. This can be confirmed by detecting suction forces at the intake opening. If the electronic valve is not working properly, repair or replacement is necessary.

4. POWERING

The PLC is programmed to start pumps sequentially with a two second delay before the next pump starts. This feature will reduce the initial incoming current load commonly associated with system startup. This delayed starting of pumps may reduce the requirements for a backup generator (Engineer of Record must approve). Note this power-up feature is not applicable when aeration pumps are left in the "Hand" position. Each PLC comes with an in-line surge protector. The surge protector should be checked periodically to ensure proper protection (see surge protector specification sheets for further details).

5. ON-DEMAND AERATION

The Cromaglass system is designed for aeration "On-Demand." Through the use of float switches, aeration and mixing pumps are turned on or off according to water level.

The float used in the on-demand aeration sequence is the "C" float. The C float is located in manway #1 and set slightly above the Low Water Discharge Float. The C float will turn on both aeration pumps P1 and P2 continuously. If the C float is not engaged, either P1 or P2 will run alternating each cycle (P1 on during odd cycles, P2 on during even cycles).

6. DISCHARGE

The first float switch in the discharge circuit is the Low-Water Discharge Float (LWDF). It is located in the Aeration Section of the second tank. The purpose of this float is to prevent a discharge if the water level is too low in the aeration section. This is necessary to maintain sufficient mixed liquor during periods of low flow.

Both the LWDF float and the Discharge Float (DF) located in the clarifier must be engaged to complete the discharge circuit. If both floats are engaged, they will signal an input on the PLC.

There is an additional control which will alternate power to the other discharge pump should the first pump fail to operate. When the PLC energizes a discharge pump it also energizes the "H" float level sensor in the clarifier. After seven minutes elapsed time if the liquid level did not drop enough to open the float switch (H), the PLC will energize the other discharge pump, activate a steady alarm light, and signal a remote dialer output.

7. GO-FAST SEQUENCE

The PLC can operate under a shortened cycle to confirm proper sequence of operations. A "GO-FAST" toggle switch in the control panel when activated will signal an input and cause the PLC to begin a shortened cycle. During the GO-FAST mode, the cycle minutes equate to seconds. For example, a 240-minute cycle will sequence through in only 240 seconds while in GO-FAST.

The operator can confirm proper operations of pumps and floats by noting the inputs and outputs on the PLC or by observing the Timeline menu of the HMI and the treatment system.

After turning GO-FAST off, use the Reset button in the control panel or the HMI to return to the preset cycle-time. Note the PLC will automatically turn GO-FAST off when four consecutive GO-FAST cycles have been completed.

8. RESET PUSH BUTTON

Resetting the PLC will return the system to the proper cycle time according to the PLC's real time clock and the system settings. The Reset feature is accomplished with either the Reset push button located in the control panel next to the Go-Fast toggle switch or via the HMI. It is recommended to use the HMI due to the "Are You Sure" prompt (see HMI instructions).

9. HIGH WATER ALARM

The high water alarm circuit consists of the "AL" float level sensor in the Solids Retention Chamber. When the liquid level raises the alarm float switch, an input on the PLC is signaled and turns on a relay output for a remote dialer and a pulsing alarm light. Additionally, a surge cycle begins if the AL float is engaged for more than one minute (see Surge Cycle for additional details).

10. SURGE CYCLE

The PLC is programmed to automatically assume a Surge Cycle, or shortened cycle, when a High Water Alarm occurs. The PLC assumes the following settings when in surge mode:

Transfer	=15 min.
Settle 1	= 20 min.
Słudge Return	= 5 min.
Settle 2	= 5 min.
Discharge	=15 min.

The surge cycle settings are automatic and not adjustable via the HMI. The PLC will also advance within the surge cycle according to the following rules:

- Rule 1.0 If the Sludge Return Float or H Float is on, start at min. 15 of surge cycle.
- Rule 2.0 If in Discharge, Settle 2, or Sludge Return phase, start at min. 45 of surge cycle.
- Rule 3.0 If neither Rule 1.0 nor 2.0 are satisfied, begin surge cycle at min. 0.

The PLC is programmed to revert to initial settings after the surge cycle is completed and the High Water Alarm has cleared. The PLC will continue to operate in surge mode until the surge cycle is completed and the High Water Alarm has cleared.

It is important to note the PLC will return to minute zero of a normal cycle after the surge cycle. The PLC will now be out of sync with the real time clock. The system must be Reset to synchronize the cycle time with the real time clock (see Reset instructions).

11. LOW AERATION SECTION ALARM

The Low Aeration Section alarm is signaled to the PLC via the Normally Closed "LA" float located in manway #2. Note all other floats with the exception of LA, LC, and EQ-DF (if an EQ tank precedes system) are Normally Open.

The LA float is suspended slightly below the LWDF float. If the water level drops below the LA float, a signal is sent to the PLC, all aeration/transfer pumps are turned off, an output is signaled for a remote dialer, and a steady alarm lamp is illuminated. The alarm lamp will remain on to inform the operator the system has undergone a Low Aeration Section alarm. To clear the alarm, simply reset the system.

The pumps will start when the water level rises sufficiently in the aeration chamber. If a Low Aeration Section alarm has occurred the LWDF float should be checked to ensure it is operational.

OVERLOAD

There may be an occasion when an extraordinary overload of incoming wastewater cannot be adequately handled through the programmed cycle. In such a situation, it may be necessary for the operator to temporarily speed up the process by limiting the aeration cycle of P3 pump. This is accomplished by changing the setting on time clock TC2 for additional discharge cycles. Due to a continuous operation of the two aeration pumps this should not affect the total aeration capabilities or effluent quality. Note that if heavy surges have caused a frequent changing of the aeration and transfer period, there is undoubtedly an indication of an overload on the system as originally sized and provisions should be made for increasing the total capacity.

Should the operator be unable to correct conditions for which these instructions can help, a phone call should be made to the nearest Cromaglass® Distributor or the Cromaglass® factory.

CROMAGLASS Sequencing Batch Reactor Operations & Maintenance Manual CA-50/60

SECTION IX

INITIAL MONITORING PHASE

Operators must keep in mind that this is a living, breathing biological community that requires attention. During initial operations, it is recommended to inspect daily. The following **Checklist** was developed to assist the owner/operator with initial start-up procedures.

- a. At minimum, one complete cycle should be observed to confirm normal operations of all systems: aeration, transfer, anoxic, settle, sludge return, and discharge would be considered a complete cycle.
- Observe float switch operations. Be sure to observe tank levels associated with current settings.
- c. Collect/observe final effluent clarity documenting any unusual characteristics (e.g., turbidity, odor, suspended solids, etc.).
- d. Note any unusual odors associated with treatment process while in aeration mode. A musty, woodsy odor is indicative of good operations.
- e. Loud noises are not normal and must be recorded.
- f. All air intakes should be checked for proper vacuum. This can be accomplished by holding a hand over PVC intake pipes.
- g. Observe initial aeration cycle and monitor dissolved oxygen (D.O.) levels. It is very important that the D.O. meets or exceeds 2 mg/l near the end of this cycle. This will ensure the microorganisms are provided a satisfactory environment necessary for biological oxidation of organic waste. If the D.O is below 1.5 mg/l, inspect manual PVC ball valves to assure they are fully open. Fully open valves will allow more oxygen to enter the system. Over-aerating can also have a negative impact on the system. This can create a floc that is dispersed resulting in a poor-settling sludge. Partially closing the same valve will reduce the oxygen supplied. Minor adjustments should only occur once per day. Time must be allowed for the microorganisms to acclimate to changes and reach steady state.

12. LOW CLARIFIER SECTION ALARM

The Low Clarifier Section Alarm is signaled to the PLC via the Normally Closed "LC" float located in manway #2. Note all other floats with the exception of LA, LC, and EQ-DF (if an EQ tank precedes system) are Normally Open.

The LC float is suspended slightly below the DF float. If the water level drops below the LC float, a signal is sent to the PLC, all clarifier pumps are turned off, an output is signaled for a remote dialer, and a steady alarm lamp is illuminated. The alarm lamp will remain on to inform the operator the system has undergone a Low Clarifier Section alarm. To clear the alarm, simply reset the system.

The pumps will start when the water level rises sufficiently in the clarifier chamber. If a Low Clarifier Section alarm has occurred the DF float should be checked to ensure it is operational.

Cromaglass CA-50/60 Siemens S7-226 Micro PLC Version 1.02

Bottom Row LED's

INPUT	SOURCE	FUNCTION
10.0	AL Float	Signal High Level Alarm
10.1	GO-FAST toggle switch	Engage Shortened Diagnostic Cycle
10.2	RESET Push Button	Re-initialize PLC/HMI
10.3	C Float	Activate Pump #1 and #2 Simultaneously
I0.4	DF Float	Enable discharge
10.5	H Float	Signal Discharge Pump Failure Alarm
10.6	F4 Float	Enable Sludge Return Pump
I1.1	LA Float	Low Water Shutoff for Aeration/Transfer Pump(s)
I1.2	LC Float	Low Water Shutoff for Clarifier Pump(s)
12.5	Address Bit	Address the PLC to Train C
12.6	Address Bit	Address the PLC to Train B
12.7	Clock Set	Resets the PLC Timeclock to 12 A.M.

Top Row LED's

OUTPUT	DESTINATION	FUNCTION
Q0.0	Dialer	High Water Alarm
Q0.1	Dialer	Discharge Pump Failure Alarm
Q0.2	Dialer	Low Aeration Section Alarm ²
Q0.3	Dialer	Low Clarifier Section Alarm ²
Q0.4	Pump #1	Aeration
Q0.5	Pump #2	Aeration
Q0.6	Pump #3	Aeration/Transfer
Q0.7	Pump #4	Sludge Return/Waste
Q1.0	Pump #5	Discharge
Q1.1	Pump #6	Discharge
Q1.5	Denite Valve	Close Denite Valve
Q1.6	Denite Valve	Open Denite Valve
Q1.7	Alarm Lamp/Buzzer	Visual/Audible Alarm Indicator(s)

¹Blinking for High Water Alarm; Steady for Pump Failure or Low Water Alarms ²RESET to clear CROMAGLASS Sequencing Batch Reactor Operations & Maintenance Manual CA-50/60

B. OPERATING INSTRUCTIONS - Mechanical Controls Models CA-50/60

CONTROL PANEL

Electrical service to control panel - 230 v, single phase, 4 wires

P1 and P2 pumps operate from Tork timer TC1. This timer is set to run 24 hours a day. The timing can be changed to alternate pumps P1 and P2 if the application warrants.

P3 transfers mixed liquor to clarifier and is controlled by Tork timer TC2. This timer is factory set depending upon which model is sold. Cycles may be adjusted to optimum performance.

EACH CYCLE CONSISTS OF:

1 hour 30 minute transfer (CA-50) 54 minute transfer (CA-60), after which TC2 microswitch drops off toggling on timers TC3 and 4 and allows clarifier to settle. Timer TC3 is set for 30 minutes. At the end of the 30 minutes, the sludge return pump will be energized and return the sludge to the aeration chamber. Level sensor de-activates this pump. TC4 is set 60 minutes or an additional 30 minutes following the sludge return event. At completion of 60 minutes of settling, discharge pump P5 or P6 will be energized to decant the clarified effluent. Discharge volume is controlled by level sensor.

NOTE: In order for the system to go into a discharge, there must be enough liquid in aeration chamber to activate the (LWDF) level sensor that is hanging nearest transfer pump in aeration chamber (even though the clarifier is full).

DO NOT SET TIMERS WITH POWER ON

AERATION SECTION

Pumps P1, P2 create an optimum amount of aeration within the main aeration chamber and comminution chamber. Although these pumps are heavy-duty sewage pumps, they should be checked periodically to assure that they have not become clogged from stringy articles.

Should the alarm system be activated and there is no noticeable excess of clogging materials in the comminution chamber, there is a possibility that P3 pump is malfunctioning. (P3 pump provides all the water transfer to the clarifying chamber, and if malfunctioning would cause water level in the entire main chamber and comminution chamber to rise and signal through the "AL" float level device.)

AIR FLOW

It is important that a programmed quantity of air flows to the entire system. A check should be made occasionally for proper aeration by first visually estimating amount of turbulence within the main aeration chamber or (if proper sequence) the settling chamber. Also aeration can be determined by placing a hand against the air intake, wherever it may be located. Adequate suction would indicate proper amount of aeration.

SECTION X

PROCESS CONTROL TESTING

The Cromaglass SBR Treatment Facility is designed to produce a high quality effluent suitable for surface or subsurface disposal provided the biological process is optimized. This chart has been developed to serve as an operational tool. Process performance is dictated by a thorough understanding of all biological processes.

	INFLUENT
SAMPLE	FREQUENCY
BOD ₅	SEMI-ANNUAL
CBOD	SEMI-ANNUAL
TSS	SEMI-ANNUAL
TKN	SEMI-ANNUAL

E	FF	L	U	E	N	17	Γ
---	----	---	---	---	---	----	---

SAMPLE	FREQUENCY				
CBOD	MONTHLY				
TSS	MONTHLY				
NH ₃ -N	MONTHLY				
NO ₂	MONTHLY				
NO ₃	MONTHLY				
pН	MONTHLY				

MIXED LIQUOR

SAMPLE	FREQUENCY
MLSS	QUARTERLY
MLVSS	QUARTERLY
SETTLOMETER	WEEKLY
ALKALINITY	QUARTERLY
рН	WEEKLY
D.O.	WEEKLY

Noture Recommend

More frequent testing will be required should final effluent quality exhibit signs of degradation (e.g., high CBOD, high TSS, increased turbidity, etc).

Note: Each regulatory agency may have specific sampling requirements. Sampling schedule may be adjusted accordingly.

Items of note should trigger flags for the operator, indicating more attention is required to reestablish high quality effluent:

- Black coloration in mixed liquor
- Low D.O. concentrations
- Offensive odors while system is under aeration
- ♦ Falling pH values < 6.0</p>
- Increasing effluent CBOD & TSS values
- Increased effluent turbidity.

Note: Manufacturer recommends this test conducted weekly.

SECTION XI

SLUDGE WASTING & SETTLOMETER TEST

A key operational tool the operator has available is the ability to increase or decrease sludge wasting. An appropriate amount of mixed liquor must be maintained in order to optimize the biological process. This is called controlling the food to microorganism ratio (F/M). The volume of wasted sludge is determined by the 30-minute Settlometer Test. No more than 10% MLSS should be wasted in a 24-hr period. Sudden process control changes must be avoided to reduce stressing the microorganisms. If a sludge holding tank was provided, a quantity of **settled sludge** can be pumped to this location. By closing the PVC sludge return valve to the head of the plant and opening the sludge wasting valve during a normal sludge return event, the appropriate biological inventory is maintained in the system. Increased organic loadings will require more supplied oxygen and reduced sludge wasting. This will result in a lower F/M ratio, resulting in more bacteria on site for degradation of substrate. Conversely, reduced loadings will result in a lower F/M).

The Settlometer test is very useful in determining when to waste sludge from the system. (Refer to Settlometer Graph Section 11-2).

To perform:

- Obtain a one-liter graduated cylinder that is properly marked.
- Fill the container to the 1000-ml mark with well mixed activated sludge. This sample should be obtained from the aeration compartment near the end of the aeration/transfer cycle.
- Place the cylinder out of direct sunlight to eliminate denitrification during the settling process.
- Begin to time settling and record percent of sludge/liquid interface volume every 5 minutes for the first 30 minutes, followed by 10-minute recordings for the next 30 minutes. Be sure to observe sludge coloration, floc-settling characteristics (e.g., fast or slow settling, fine pin floc in supernate, etc.).

6		5
		_
	900-	
	800-	
	700-	
ORGANIC	600-	
DVERLOAD	450 500-	
OPERATING	400-	
RANGE	250 300-	
	200-	
UNUERLUAU.	100 -	-
		_

õ

Page 11-1

Optimum settling should yield a 30-minute test ranging between 250 ml/l and 450 ml/l. Results greater than 450 ml/l indicate organic overloading is occurring and sludge wasting should be increased. Tests yielding less than 250 ml/l indicate under-loading and wasting must be reduced. No more than 10% of inventory should be wasted per day.

Sludge should be wasted during normal sludge return cycle, if possible. This will assure a higher concentration of bacteria. To waste, close valve in the sludge return line (which returns sludge from the clarifier to the aeration chamber) and open valve in line leading to the sludge holding tank. For systems that do not have a supplied tank, secure a septic hauler to remove sludge from system. Hauler should place suction hose in aeration compartment with both P1 and P2 pumps running to maximize mixing.

Caution: Do not remove excessive amounts of sludge resulting in a settlometer test of less than 250 ml/l. In doing so, the process will be deprived of a sufficient quantity of bacteria to provide adequate treatment and ultimately result in degrading effluent quality. Should this occur, no further wasting of biological solids should take place in order to rebuild biomass inventory.

Following the sludge-wasting event, return sludge valves to normal factory settings.



SETTLOMETER GRAPH

Page 11-2

SECTION XVIII

TROUBLESHOOTING GUIDE

PROBLEM

1. White, billowing foam on surface in aeration section. CAUSE

SOLUTION

Overloaded aeration tank, low Mixed Liquor Suspended Solids (MLSS) due to startup. Will resolve itself.

Excessive sludge wasting from process tanks.

Toxic waste introduced into process, severe temperature change in influent, or large change in influent pH.

2. Thick, scummy, dark foam in aeration section MLSS too high

DO too low

Change in influent strength or pH.

Do not waste sludge during start-up period.

Restrict sludge wasting so the settleable solids test confirms a minimum of 250 ml sludge level.

Establish new activated sludge after eliminating toxicity. Eliminate sources of toxicity, temperature and pH changes. Use pH adjustment equipment.

Waste sludge

Test for DO, if <2 mg/l increase air.

Increase air. Check for source of problem, eliminate if possible.

CAUSE

PROBLEM

3.	Dark brown, black sudsy foam or mixed liquor color. Septic or sour odor.	Anaerobic conditions in aeration section, due to toxic influent or aeration equipment failure.	Check influent for cause of toxicity. Check for pump failure or clogged venturi(s)	
4.	Clouds of fluffy sludge rising in areas of clarifier. Mixed liquor settles until process is back to	Improper organic loading or change in DO level.	Check DO, reduce if too high. Decrease or eliminate sludge wasting sl	owły.
			optimum parameters	
		Filamentous organisms cause such as fats, grease,	Check influent for likely	
			ground water infiltration, etc. and eliminate cause.	
			Check for low DO	
			To remove, lightly chlorinate influent with caution.	
		Wastewater nutrient deficiencies.	Check nutrient level in influent wastewater. Nutrient addition may be required.	
		Low DO in aeration section.	Increase air to raise DO to at least 2mg/l.	
		pH in aeration section is <6.5.	Eliminate cause of low pH if possible. If not, add an alkaline agent such as caustic soda or lime, with care, to influent.	
	5. Solids in effluent	MLSS too high, high solids level in clarifier.	Do settleable solids test. If high, waste sludge to reduce solids to 250-300 ml	
		Poor settling in clarifier	MLSS too low due to start- up or toxic kill. Do not waste sludge, increase MLSS. Check liquid in aeration section for high acidic, grease, or alkaline levels.	

SOLUTION

	PROBLEM	CAUSE	SOLUTION
	5. (continued)		Eliminate at source if possible.
		High solids level in clarifier.	Check sludge return pump operation. If OK check sludge return float in clarifier. Lower if necessary to remove more sludge (factory setting at 20" top of float to tank top. check and replace TC-3 if necessary.
		Light colored pin floc on clarifier surface	Check DO in aeration section, reduce to <4.0mg/l if high.
		Discharge pumps operate too long, discharge solids	Check discharge float, replace if necessary.
		Mixed liquor becoming septic.	Check aeration pump operation. Adjust floats to provide constant aeration until DO rises to acceptable parameters.
		Low water float failure	Replace float
6.	High water alarm	Hydraulic overload	Correct overload cause; or install equalization tank; or increase system capacity.
		Discharge pump failure	Repair/replace discharge pump.
		Transfer pumps not operating	Check operation of TC-2 for proper functioning.
			Repair/replace transfer pump.
7.	Discharge pump(s) not operating	Improper signal from low water float	Check and replace if necessary.
		Timer malfunction	Check operation of TC-2 for energizing TC-3 and TC-4 timers. If OK, check and replace TC-4 if necessary.
		Pump failure	lf energized – repair/replace pump.