



## Water Authority—Cayman

### OWMP : Onsite Wastewater Management Programme

#### STANDARD TREATMENT SYSTEMS Approved for Installation in the Cayman Islands

Last Update: June 2017

#### Requirements:

1. All Standard Treatment Systems shall be of a design having third-party certification (NSF/ANSI Standard 40 or equivalent) of producing an effluent quality that meets limits of 30 mg/L Biochemical Oxygen Demand (BOD<sub>5</sub>) and 30 mg/L Total Suspended Solids (TSS).
2. Proposals for Custom Treatment Systems will only be considered in cases where wastewater flows exceed the hydraulic or organic treatment capacity of Standard Treatment Systems having third-party certification. Contact [development.control@waterauthority.ky](mailto:development.control@waterauthority.ky) for more information.
3. Proposals for Standard Treatment Systems shall be submitted per the Standard Proposal Form (attached).

MAKE	MODEL(S)	SUPPLIER	CONTACT	eMAIL ADDRESS	PHONE #
<a href="#">BioMicrobics</a>	FAST	Entech Ltd.	Troy Whittaker	<a href="mailto:entech@candw.ky">entech@candw.ky</a>	947-9253
<a href="#">Clearstream Systems</a>	N series	Wastewater Purification Systems Ltd.	Bo Miller	<a href="mailto:wastewaterpurification@gmail.com">wastewaterpurification@gmail.com</a>	916-0003
<a href="#">Delta Whitewater</a>	DF series	Entech Ltd.	Troy Whittaker	<a href="mailto:entech@candw.ky">entech@candw.ky</a>	947-9253
<a href="#">JET</a>	J series	Waste Away Systems & Service	George Wilks	<a href="mailto:gwilks433@gmail.com">gwilks433@gmail.com</a>	516-0003
<a href="#">KEE</a>	NuDisc	several, as listed below			
<a href="#">Klargester</a>	BioDisc	several, as listed below			
		Advanced Fire Ltd.	Jim Ross	<a href="mailto:jim@advancefireltd.com">jim@advancefireltd.com</a>	916-4240
		Androgroup Ltd.	Steven Walsh	<a href="mailto:service@andromep.com.ky">service@andromep.com.ky</a>	949-8000
		Cayman Mechanical Co.	Charlie Bauman	<a href="mailto:charles.bauman@caymanmechanical.com">charles.bauman@caymanmechanical.com</a>	949-6161

#### Notes:

1. Complete Proposals for Standard Treatment Systems will be reviewed within 14 days of receipt.
2. Some of the systems listed have a single authorised local dealer while others may be available to various local suppliers/ installers.
3. This list is for informational purposes and does not constitute an endorsement of or preference for any single company or make of system.
4. For consideration of a system not listed here, contact the Water Authority for requirements for obtaining approval.